



FIRE FLOW TEST REPORT

Test Date:

Location:

Observation Hydrant Pressures

Static (before)	72	PSI
During	58	PSI
Static (after)	72	PSI

Number of hydrants flowed in test:

Flow Hydrant(s)	Outlet	Coef.	Pressure (PSI)	Flow	Hydrant Notes
Hydrant 1	2.5	0.9	55	1245 GPM	
Hydrant 2	2.5	0.9	45	1126 GPM	
				0	
				0	
Total				2371 GPM	

Desired Residual Pressure
20 PSI

Flow available at desired residual Pressure
4816 GPM

Prepared by: Scott B with Josh, Jose, and Jake

Date: 12/8/2022

Qr flow available at desired residual pressure
3386 Qf flow during test
60 hr pressure drop to desired residual pressure
33 hf pressure drop during test

Formula to calculate discharge at specified residual pressure.
(hr and hf are raised to the power of 0.54)

$$Q_r = Q_f \times \frac{h_r^{0.54}}{h_f^{0.54}}$$


$$Q_r = 4676.179$$

2-1/2" Fitting

Coefficient	Formula
0.9	$Q=167.79p^{1/2}$
0.8	$Q=149.15p^{1/2}$
0.7	$Q=130.51p^{1/2}$

Pressure (p)

Coefficient	2.5" Flow GPM
0.9	530.5985686
0.8	471.653713
0.7	412.7088574



4" Fitting

Coefficient	Formula
0.9	$Q=429.55p^{1/2}$
0.8	$Q=381.82p^{1/2}$
0.7	$Q=334.10p^{1/2}$

Pressure (p)

Coefficient	4" Flow GPM
0.9	1358.356369
0.8	1207.420856
0.7	1056.516966